

February 28, 2023

CITY OF MERCED
ENGINEERING DEPARTMENT
678 W. 18th Street, Merced, CA 95340

ADDENDUM NO. 1

To ALL PROSPECTIVE BIDDERS
Under Specifications for the Construction of the
ORCHARD LANE SEWER REPLACEMENT
PROJECT NUMBER 119025

For which bids are to be received by the City of Merced Purchasing Agent, at the
Purchasing Conference Room, at 2525 "O" St., Merced, CA 95340, until 2:00 PM on
Tuesday, March 14, 2023

The following revision to the Plans shall be made:

Item 1: PLANS: - SHEET 3 have been revised by the following:

A. Revision to Construction Note 5 by the following:

- The existing manhole is to be "Removed" only, not "Replaced". The existing 12" line needs to be tied into the new manhole at approximately 7 linear feet and paid for under the bid item "Remove Manhole".
- Note (P) by that manhole calls out for 14" DR 19 HDPE to be extended 7.35'. The actual size of the sewer is 12" and can be replaced with SDR 26 sewer or approved equal.
- The call out on that line states "20" Sewer". It's actually a 12" Sewer.



Jason Adam Brown, P.E.
Project Engineer, Kleinfelder



Michael R. Beltran II, P.E.
City Engineer

Name of Bidder or Firm: _____

THIS ADDENDUM MUST BE SIGNED AND RETURNED WITH BID PROPOSAL.

ADDENDUM NO. 1 has been received and incorporated into the bid proposal.

Received By: _____

Date : _____ Plan holder : _____

NOTE: RECEIPT OF THIS ADDENDUM MUST ALSO BE ACKNOWLEDGED IN THE CONTRACTOR'S BID PROPOSAL.

