



CITY OF MERCED

MERCED

*Office of the City Engineer ◊ Telephone (209) 385-6846 ◊ Facsimile (209) 385-6211
678 West 18th Street, Merced, Ca. 95340*

February 12, 2024

**RE: R Street Sidewalk Replacement Childs to 13th Street
Project # CP220024**

Subject: Response to Request for Information (RFI)

Question 1 – On a very hot day, can pours began at 7:00 AM?

Answer – Yes

Question 2 –Is the City providing a staging area?

Answer – Contractor is responsible for their own staging.

Question 3 –Will work be allowed on the weekend?

Answer – No

Question 4 –Is compaction testing required at each site?

Answer – Testing must be performed for each location.

Question 5 –How will construction water be obtained?

Answer – Fire hydrate water meter can be pick up at Public Work. There is a \$4000.00 deposit and a \$50.00 fee.

Question 6 –Is SWPPP required since the project is less than 1 acre?

Answer – Water pollution control best management practices should be used on this project to protect the storm system. A SWPPP is not needed if soil disturbance including stockpiles and staging area will be less than 1 acre.

Michael Wegley, P.E.
City Engineer